

Omaha Tribe
Environmental protection Department
204 Main Street
Walthill, Ne. 68067


June 25, 2004

Fuel Plaza
17223 W. 210th St.
Onawa, Iowa 51040
Phone (712)423-3979

I Delmar Parker the UST Tech with the Omaha Tribal Environmental Protection Agency and Mr. Ed Wakeland an Inspector with the U.S. Environmental Protection Agency Region 7 Kansas City, Kansas traveled to Onawa Iowa to conduct an Inspection on the Underground Storage Tanks located at the Fuel Plaza, we were meet by Supervisor Cheryl Cook and Herman Harlan, Cheryl provided the information that was requested and information from the Automatic Tank Gauge was provided. The station utilizes an EECO 2000 (ATG) system service for both gasoline and diesel. The station operates with 6 tanks, tank 1-2-3 is 10,000 gal filled with gasoline product and tank 4-5-6 is 18,000 gal filled with diesel product .

Mr. Wakeland inspected the tanks outside, he noticed that the leak detector is not an valuable leak detector because the tank my leak 3 gals per hour before detected, the leak detector was found to be put up to high so it wouldn't detect the product, Mr. Wakeland informed Cheryl that he'll contact the main head quarters to see if that is OK to have the leak detector put that high.

Mr. Wakeland also noticed that the Fuel Station doesn't have a shut off alarm to alarm the operator of an over fill of product. Mr. Wakeland informed Cheryl that he'll be writing the Fuel Plaza a letter of the corrections that needed be corrected.

Delmar Parker

Omaha Tribe EPA UST Technician